

TENT GUIDELINES

All tents 200 square feet or larger must have a current (within the last 12 months) Florida or other **state certified minimum 2A:10B: C portable fire extinguisher**. All cooking tents (regardless of size) require a current Florida or other state certified Class “K” portable fire extinguisher in addition to the 2A:10B: C extinguisher. Certified fire extinguishers may be purchased from any fire and safety equipment company. **Fire extinguishers purchased from most retail stores are not certified and will not be accepted.**

Tents must be flame retardant and shall meet the flame propagation performance criteria specified by NFPA 701. All tents must be certified by an approved testing agency and the vendor shall provide evidence of the flame spread certification. The tag must be visible on the tent for ease of inspection. Non-flame retardant tent fabrics or materials such as retail store camping tents or tarps do not meet the NFPA 701 Standard and will not be accepted.

All tents and/or canopies must be weighted or tied down to prevent accidental overturn from excessive winds and/or sudden storms in a manner acceptable to the authority having jurisdiction (AHJ).

I have read and will comply with these requirements.

Contact Name (Print) Address, City, Contact Phone Number

Signature